

## Ports used by Normalink devices.

The following control devices use port 2234 for UDP communication:

- IDNG-MG
- IDNGR16K
- IDNG-10ES
- C24i
- IDALING
- IRS485

The IDNG-MG gateway can also communicate via UTP using the following ports:

COMPORTWEB 4322  
SERVER\_PORT\_SSL 443  
SERVER\_PORT\_FTP 21  
SERVER\_PORT\_MASTER 2236  
SERVER\_PORT\_CLIENT 2237  
SERVER\_PORT\_RAW 2238

Normalink and BMS can work in local mode (UDP) using port 2234 and through the master gateway (TCP) using the aforementioned ports.